



The County

PRINCE EDWARD COUNTY ♦ ONTARIO

PRINCE EDWARD COUNTY ADDENDUM No. 1

Date: Wednesday, December 27, 2017
Contract: 2017-EDW-76
**PICTON HEIGHTS RESERVOIR WATERMAIN IMPROVEMENTS
AND ILLUMINATED SIDEWALK**

I. DIRECTIVE

This Addendum shall form an integral part of the plans and specifications for the above-mentioned project and shall be read in conjunction therewith. This Addendum shall, however, take precedence over all requirements of the previously issued drawings, specifications, or addenda with which it may prove at variance, unless otherwise clarified by the Engineer.

II. CLARIFICATIONS

1. Part A – Instructions to Bidders – Section 2 - Tender Delivery & Opening (*pg 3*)
The NEW closing date and time for submitting tender has been extended from 2:00:00 p.m., Local Time, Tuesday, January 9, 2018 to 2:00:00 p.m., Local Time, **Tuesday, January 23, 2018.**
2. Part A – Instructions to Bidders – Section 5 - Inquiry (*pg 5*)
The NEW closing date and time for submitting inquiries, in writing, has been extended from 4:00 p.m., Local Time, Friday, December 29, 2017 to 4:00 p.m., Local Time, **Friday, January 12, 2018.**

III. REVISIONS TO PART C - FORM OF TENDER

1. Agreement to Contract and Schedule of Prices
In the Section - Agreement to Contract and Schedule of Prices, for Sub-contractors, remove existing line item “Horizontal Directional Drilling” in its entirety and replace with “Rock Boring or Open Cut”.

IV. REVISIONS TO TERMS OF REFERENCE

1. Special Provisions – General, Item 36 Occupational Health and Safety Act 1991 – Designated Substances

ADD Note: “The existing watermain along Union and Church street, and the connecting watermains to other streets are anticipated to be Cast Iron or Ductile Iron, and as such may contain **lead joints**. Undertake the necessary safety precautions when working around the existing watermain, for connection to the new watermains or for abandoning”.